

## PRESSURE EQUIPMENT DIRECTIVE 97/23/EG H&R Gruppe

As of 1. Januar 2011

If the scope of supply includes pressure equipment in accordance with the Pressure Equipment Directive 97/23/EC the requirements incumbent in them must be complied; any costs resulting from them are also included in the scope of supply.

For the completion of the conformity assessment by the manufacturer the minimum requirements to be observed are as follows:

- Receptacles: Module G = EC-unit verification
- Steam boilers: Module G = EC-unit verification
- Piping: Module B1 + F = EC-design examination + product verification or Module A1 (in case the design is made available elsewhere)
- Safety accessories: Module G = EC-unit verification
- Pressure-bearing Components: Module H = Umfassende Qualitätssicherung
- Assemblies: Module G = EC-unit verification

The AD 2000 Standard must be applied for modules G and B1 + F for complying with the essential safety requirements of the Pressure Equipment Directive; for module H it shall apply by analogy.

The AD 2000 Standard must be applied for pressure equipments of the category 1 and 2.

Should part of the delivery deviate from these requirements, it must be clarified with the buyer before the order is placed.

When selecting a module please always indicate the classification of the pressure equipment and the device designation.

In case you would like to offer several modules, please always indicate the price difference.

### Piping

Only materials according to the corresponding harmonised material standards should be used. After consultation the appropriate materials from a predecessor standard can be accepted.